



IEC 61850 Certificate

Level A¹

No. D 089191 0022 Rev. 00

Issued to:

Schneider Electric Industries SAS
35 rue Joseph Monier,
92500 Rueil-Malmaison,
France

For the server product:

Easergy P5F30
Feeder Protection
Software Version: V01

Issued by:

TÜV SÜD CERTIFICATION AND TESTING (CHINA) CO., LTD
SHANGHAI BRANCH
Communication Protocols
No.16 Lane 1951 Duhui Road
Shanghai, 201 108,
People's Republic of China

The server product has not been shown to be non-conforming to:
IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1
Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² version 1.2.6 with product's protocol, model and technical issue implementation conformance statements: "Schneider Electric Easergy P5 IEC 61850 Server Conformance Statement Ed 2: Chapter 2 PICS", "Schneider Electric Easergy P5 IEC 61850 Server Conformance Statement Ed 2: Chapter 3 MICS", "Schneider Electric Easergy P5 IEC 61850 Server Conformance Statement Ed 2: Chapter 5 TICS" and product's extra information for testing: "Schneider Electric Easergy P5 IEC 61850 Server Conformance Statement Ed 2: Chapter 4 PIXIT".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test):

1	Basic Exchange (24/26)	9a	GOOSE Publish (13/13)
2	Data Sets (4/7)	9b	GOOSE Subscribe (12/14)
2+	Data Set Definition (24/24)	12a	Direct Control (6/18)
4	Setting Group Selection (4/4)	12b	SBO Control (12/27)
5	Unbuffered Reporting (21/21)	12c	Enhanced Direct Control (8/20)
6	Buffered Reporting (30/30)	12d	Enhanced SBO Control (13/28)
		13	Time Synchronization (4/7)

This Certificate includes a summary of the test results as carried out at TÜV SÜD Certification and Testing (China) Co., Ltd Shanghai Branch in P.R. China with SimFlex CS Ed.2 version 2.0 with test suite 1.0-1.2-0.5 and Wireshark version 2.0.4. This document has been issued for information purposes only, and the original paper copy of the TÜV SÜD report: No. 705001600307-00, version 1.0 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to TÜV SÜD by Schneider Electric Industries SAS. The manufacturer's production process has not been assessed. This certificate does not imply that TÜV SÜD has certified or approved any product other than the specimen tested.

Shanghai, January 30, 2019

Yifan WANG
Technical Certifier

Cong WANG
Test Engineer

¹ Level A - Independent Test lab with certified ISO/IEC 17025 Quality System

² Test Procedure Change List

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

No. D 089191 0022 Rev. 00

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL version 1.2.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv9, sSrv10, sSrv12, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs11, sDs13, sDs14, sDsN1cd sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs12, sDsN11, sDsN12
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp13, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr13, sBr23, sBr24
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11	sGop1, sGop2b, sGop5, sGop6, sGop7, sGopN1, sGopN2
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	
12a Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl13, sCtl16
12b SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl6, sCtl16, sCtl27
12c Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl13, sCtl14, sCtl16, sCtl26
12d Enhanced SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl6, sCtl16, sCtl26
13 Time sync	sTm1, sTm2, sTmN1	sTmN2

Zertifizierungsvertrag

Grundlage für die Zertifikatserteilung ist die Prüf- und Zertifizierungsordnung von TÜV SÜD Product Service.

Mit Erhalt des Zertifikates erkennt der Zertifikatsinhaber die jeweils gültige Fassung der Prüf- und Zertifizierungsordnung an (www.tuev-sued.de/ps_regulations) und wird somit Partner im Zertifiziersystem von TÜV SÜD Product Service.

Certification contract

Certification is based on the TÜV SÜD Product Service Testing and Certification Regulations. On receipt of the certificate the certificate holder agrees to the current version of the Testing and Certification Regulations (www.tuv-sud.com/ps_regulations) and thus becomes partner in the TÜV SÜD Product Service Certification System.

认证合约

认证基于 TÜV SÜD 产品服务《测试及认证准则》。获得证书即表明证书持有者接受当前版本的《测试及认证准则》（见 www.tuv-sud.com/ps_regulations）并成为 TÜV SÜD 产品服务认证系统内的合作伙伴。

認証契約

認証は TÜV SÜD Product Service の試験認証規約に基づく。認証書保持者は認証書を受領することにより最新の試験認証規約(www.tuv-sud.com/ps_regulations)に同意したものとします。その結果、TÜV SÜD Product Service 認証システムのパートナーとなる。

Contrato de certificação

A certificação se baseia nos Regulamentos de Testes e Certificação do Grupo TÜV SÜD. Ao receber o certificado, o Fornecedor, titular do certificado concorda com a versão atual dos Regulamentos de Testes e Certificação do Grupo TÜV SÜD (www.tuv-sud.com/ps_regulations) e assim, torna-se parceiro no Sistema de Certificação de Produtos e Serviços TÜV SÜD.

Prinzipielle Voraussetzung für die Gültigkeit des Zertifikates:

- Gültigkeit der zitierten normativen Prüfgrundlage(n) ist gegeben und zusätzlich bei Zertifikaten mit Berechtigung zur Verwendung eines Prüfzeichens bzw. bei Zertifikaten für QM-Systeme:
- Voraussetzungen für vorschriftsmäßige Fertigung werden eingehalten.
- Die Fertigungs- bzw. Betriebsstätten werden regelmäßig überwacht.

Requirements for the validity of the certificate in principle:

- Validity of the quoted test standard(s) In addition, for certificates with the right to use a certification mark and for QM certificates:
- Conditions for an adequate manufacturing are maintained
- Regular surveillance of the facility is performed

维持证书有效性的原则要求：

- 认证所依据标准的有效性
- 此外，对于授权可使用认证标志的证书和质量管理体系证书：
- 保持充分的生产条件
 - 生产场地通过定期的监督

認証書の有効性に関する原則的な要求事項

- 引用している試験規格が有効である
- さらに認証マークの使用を許諾された認証書や品質マネジメント認証書は：
- 適切な製造の条件を維持している
 - 定期的な工場監査を実施している

Requisitos para a validade do certificado (em princípio):

- Validade da(s) norma(s) de ensaio(s) referenciada(s).
- Adicionalmente, para os certificados com o direito ao uso da marca de certificação e para certificados de SG:
- Condições de fabricação adequada estão mantidas.
 - Auditoria de monitoração realizada regularmente.